



# CHECK LIST – FIRE CONSTRUCTION PERMIT

SAN JOAQUIN COUNTY COMMUNITY DEVELOPMENT DEPARTMENT

1810 E. HAZELTON AVENUE, STOCKTON CA 95205

BUSINESS PHONE: (209) 468-3121

INSPECTION REQUEST-24 HOUR RECORDER: (209) 468-3165

CHECKLIST	
THE FOLLOWING INFORMATION AND DOCUMENTATION MUST BE SUBMITTED TO DEVELOPMENT SERVICES BEFORE YOUR APPLICATION CAN BE PROCESSED.	Check-off
1. One completed Application	
2. The submittals shall be per the following:	
a. Use the following link for Electronic Plan Submittal requirements: <a href="https://www.sjgov.org/commdev/cgi-bin/cdyn.exe?grp=building&amp;htm=gopost">https://www.sjgov.org/commdev/cgi-bin/cdyn.exe?grp=building&amp;htm=gopost</a>	
b. Fire Sprinkler plans and calculations shall include all items per Chapter 6 of NFPA 13.	
c. All fire suppression systems shall be designed per the applicable current adopted codes.	
d. Designed by a Fire Protection Engineer.	
e. The California State License Number shall be on the plans.	
f. The preferred paper size is 24" by 36".	
g. Cover sheet of plans shall have a space for approval stamps in the lower right hand corner.	
h. Reference sheets shall be a separate file.	
i. Hydraulic calculations shall be a separate file.	
j. Hydraulic calculations shall have a cover sheet for approval stamps.	
k. Material submittals shall annotate the specific items being installed.	
l. If the underground is not a part of the submittal, an explanatory statement or an underground reference set of plans shall accompany the submittal.	
m. Plans for warehousing must show storage arrangements (shell building excluded).	