



## RESIDENTIAL BACK-UP GENERATOR CHECKLIST

Please submit two copies of the following information:

1. Site plan showing all structures and property lines, location of proposed generator, transfer switch, electrical service panel and fuel gas source.
2. Manufacturers Installation manual and specifications.
3. Pad and attachment details required by the manufacturer.
4. One line electrical diagram including: Kw output of generator, loads that will be backed up, grounding/bonding, size of conduit and conductors.
5. Fuel gas source, piping, size, and length.

Please contact: Air Pollution Control District for generators exceeding 50 h.p.(37.2Kw)

A.P.C.D.  
4800 Enterprise Way  
Modesto, Ca.  
(209) 557-6400