

PRESCRIPTIVE COOL ROOF and ADDITIONAL INSULATION REQUIREMENTS for NON-RESIDENTIAL, HIGH-RISE RESIDENTIAL and HOTEL/MOTEL REROOF

When more than 50% or 2000 ft2 (whichever is less) of an existing roof is being replaced, cool roofing and added insulation are required. Cool roof products must meet or exceed the values specified in Table A and be tested and labeled by the Cool Roof Rating Council (CRRC). The CRRC's Rated Product Directory can be found at <u>www.coolroofs.org</u>. Based on the information in Tables A&B, please provide the following information for the proposed roof covering.

CRRC Product ID Number	Roof Slope	Aged Solar Reflectance	Thermal Emittance	SRI

TABLE A							
	Minimum 3-year	Minimum					
Roof Slope	aged solar	Thermal	SRI				
-	reflectance	Emittance					
Nonresidential							
≤2:12	0.63 ¹	0.75	75				
>2:12	0.20	0.75	16				
High-rise residential, hotels & motels							
≤2:12	N/A	N/A	N/A				
>2:12	0.20	0.75	16				

1 Aged solar reflectance less than 0.63 is allowed provided the minimum roof/ceiling insulation specified in Table B is installed.

TABLE B

Roof/ceiling insulation tradeoff for aged solar reflectance

Aged Solar Reflectance	Metal building Climate Zone 1-16 U-Factor	Wood Framed and other. All Climate Zones other than 6-8
0.62-0.56	0.038(R-30)	0.032(R-32)
0.55-0.46	0.035(R-30)	0.030(R-34)
0.45-0.36	0.033(R-30)	0.029(R-35)
0.35-0.25	0.031(R-33)	0.028(R-36)

Cool roofing is not required if any of the following applies. Please select any that apply:

Cool roofing is not required if the roof area is covered by integrated photovoltaic panels or integrated solar thermal panels; **or**

The roof construction has a thermal mass of at least 25 lb/ft2installed over the roof membrane

Applicant's	Signature	

 \square

_____Date _____