

Environmental Health Department

Pool and Spa Closures 2016-2019

Name	Site Address	Record ID	Activity Date	Service	Program/Element	Comments
ALMONDWOOD EST HOA	800 AZALEA ST	PR0360305	8/7/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Major violation corrected. Pool reopened.
AMERICAN INN	550 W CHARTER WAY	PR0360021	6/24/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Facility was closed due to chlorine levels being less than 1.0 PPM chlorine.
AMERICAN INN	550 W CHARTER WAY	PR0360021	7/29/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed for low pH
AMERICAN INN	550 W CHARTER WAY	PR0360021	6/24/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Violation corrected, facility is operational again.
AMERICAN INN	550 W CHARTER WAY	PR0360021	7/29/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened
AMERICA'S BEST VALUE INN	1920 E YOSEMITE AVE	PR0506638	7/3/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	ok to reopen pool
ASPIRE APARTMENT HOMES	2725 PAVILION PKWY	PR0541519	7/30/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened at 2:15pm - Major violations corrected.
AVALON PLACE APARTMENTS	198 NORTHGATE DR	PR0360099	7/19/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to high free chlorine and high pH.
AVALON PLACE APARTMENTS	198 NORTHGATE DR	PR0360099	7/19/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	OK to re-open pool at 12:13pm. Free chlorine and pH levels are within range.
BAUM, JAMES W	471 ALMOND DR	PR0360304	7/17/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool is reopened after the major violations are corrected.
BECKMAN ESTATES HOA	771 BRANDYWINE DR	PR0360007	8/1/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed
BEST WESTERN HOTEL	811 W CLOVER RD	PR0503954	7/25/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened at 11:05am
BIRCHES APARTMENTS	8003 N EL DORADO ST	PR0360348	6/14/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed.
BIRCHES APARTMENTS	8003 N EL DORADO ST	PR0360348	6/16/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened.
BRIDLE PATH APTS	1619 E BRIDLE PATH PL	PR0360614	7/22/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	spa closed
BROOKSIDE CROSSING APTS (PHASE I)	5322 FEATHER RIVER DR	PR0360011	8/18/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED
BROOKSIDE CROSSING APTS (PHASE I)	5322 FEATHER RIVER DR	PR0360011	7/30/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-inspection of chlorine levels. Chlorine at acceptable level, 9.8ppm, pool re-opened.
BROOKSIDE CROSSING APTS (PHASE I)	5322 FEATHER RIVER DR	PR0360011	8/18/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	RE-OPEN POOL

BROOKSIDE CROSSING APTS (PHASE II)	5301 FEATHER RIVER DR	PR0360043	8/18/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED
BROOKSIDE CROSSING APTS (PHASE II)	5301 FEATHER RIVER DR	PR0360043	8/18/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	RE-OPEN POOL
BUDGET INN & SUITES OF STOCKTON	3473 W HAMMER LN	PR0360575	6/14/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed.
BUDGET INN & SUITES OF STOCKTON	3473 W HAMMER LN	PR0360575	6/16/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened.
BUDGET INN & SUITES OF STOCKTON	3473 W HAMMER LN	PR0360575	7/28/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened.
CALIFORNIA INN	4100 E WATERLOO RD	PR0360089	7/3/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened. Major violation corrected.
CAMBRIDGE COURT APTS	6507 DANNY DR	PR0507152	8/18/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	pool is reopened.
CAMBRIDGE PLACE COA	445 ALMOND DR	PR0360012	8/1/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed
CAMBRIDGE PLACE COA	445 ALMOND DR	PR0360012	7/16/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool is re opened after provide a life ring complying with code.
CAMBRIDGE PLACE COA	445 ALMOND DR	PR0360012	8/4/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	pOOL reopens
CAPTAINS COVE APTS	349 S UNION RD	PR0360506	6/28/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED at 1:30 pm (high free chlorine and high pH).
CAPTAINS COVE APTS	349 S UNION RD	PR0360506	6/28/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-opened pool at 4:10pm. Free chlorine and pH are within the appropriate range.
CEDAR CREEK PROPERTIES LP	9430 WESTMORA CT	PR0360327	8/3/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed.
CEDAR CREEK PROPERTIES LP	9430 WESTMORA CT	PR0360327	8/2/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool is reopened after major violations are corrected. pH is now 7.2 and free chlorine is 5.2 ppm.
CEDAR CREEK PROPERTIES LP	9430 WESTMORA CT	PR0360327	8/5/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	pool reopens
CEDAR SQUARE COA	1414 PAJARO AVE	PR0360018	6/30/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED - high free chlorine.
CEDAR SQUARE COA	1414 PAJARO AVE	PR0360018	7/21/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to low pH.
CEDAR SQUARE COA	1414 PAJARO AVE	PR0360018	7/21/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened. Pool pH is now within range.

CEDAR SQUARE COA	1414 PAJARO AVE	PR0360018	6/30/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	POOL RE-OPENED
CHATEAU APARTMENTS LODI	200 W TURNER RD	PR0360023	7/18/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Reopened Pool
CLAREMONT GARDEN APARTMENTS	820 N LOWER SACRAMENTO RD	PR0360329	8/25/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed
CLAREMONT GARDEN APARTMENTS	820 N LOWER SACRAMENTO RD	PR0360329	8/25/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened.
CLIPPER COVE APARTMENT	7611 LIGHTHOUSE DR	PR0360025	8/14/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Received an email from the pool operator showing that light had been repaired. I told him that is ok to re-open the pool.
COLONIAL PLAZA APARTMENTS	8295 KELLEY DR A	PR0360609	7/20/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed.
COLONIAL PLAZA APARTMENTS	8295 KELLEY DR A	PR0360609	8/5/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened.
COMFORT INN	14730 S HARLAN RD	PR0516548	7/26/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool has had levels of pH lowered to 7.4. Pool is permitted for re-opening.
COUNTRY MANOR MOBILE ESTATES	17251 N TRETHERWAY RD	PR0360334	6/11/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closure due to no free chlorine and high pH.
COUNTRY MANOR MOBILE ESTATES	17251 N TRETHERWAY RD	PR0360334	6/12/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool is re opened after correcting the major violations.
COURTYARD BY MARRIOTT	3252 W MARCH LN	PR0507199	6/13/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to high chlorine level
COURTYARD BY MARRIOTT	3252 W MARCH LN	PR0507199	6/14/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool and spa reopened
DAYS INN	4219 E WATERLOO RD	PR0360138	6/26/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Major violations observed at the main pool. Pool is closed till violations are corrected.
DELTA GARDEN APARTMENT	1123 W SWAIN RD	PR0360438	8/15/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-inspection for low chlorine. Chlorine levels were observed to be at 8.4ppm at the time of re-inspection and the pool is ok to be opened.
DELTA QUAIL APARTMENTS	1919 QUAIL LAKES DR	PR0360032	8/8/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool water tested fine. Re-opened.
DELTA VIEW APARTMENTS 1 LLC	802 W WEBER AVE	PR0360034	7/3/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed due to low pH
DELTA VIEW APARTMENTS 1 LLC	802 W WEBER AVE	PR0360034	7/19/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Chlorine level is now acceptable. Pool re-opened
DELTA VIEW APARTMENTS 1 LLC	802 W WEBER AVE	PR0360034	7/5/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	ok to reopen pool
EASTWOOD MANOR COA	146 E GRANT LINE RD	PR0360346	7/15/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Received picture in a text of a new rope on the life ring. Ok to re-open. See file.

ECONO STUDIOS	4540 N EL DORADO ST	PR0360055	6/8/2017	001 - ROUTINE INSPECTION - Operating Permit	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed. OIR emailed to psluthra@gmail.com and justswimmy2@gmail.com
EL RANCHO MOBILEHOME PARK	1830 E YOSEMITE AVE	PR0360038	7/20/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED. No chlorine in pool.
EL RANCHO MOBILEHOME PARK	1830 E YOSEMITE AVE	PR0360038	7/25/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	RE-OPEN pool.
EVERGREEN GARDENS APARTMENTS	1305 EL MONTE ST	PR0360354	6/8/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to lack of safety equipment and high free chlorine
EVERGREEN GARDENS APARTMENTS	1305 EL MONTE ST	PR0360354	6/20/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	ok to re-open pool
FAIRFIELD INN	2410 NAGLEE RD	PR0515193	8/2/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-opened pool
FAIRFIELD INN	2410 NAGLEE RD	PR0515193	8/2/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-inspection at regulated pool. Spa closed 7-30-19. OK to re-open given at 10:25am. Remaining minor violations: railing is wobbly, combined chlorine is 1.0ppm, CYA is greater than 100ppm, pool records need to be maintained, and the pool need to be vacuumed. Inspection report e-mailed to dorine
FRENCH CAMP RV PARK LLC	3919 E FRENCH CAMP RD	PR0506211	8/1/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed for cloudy pool and low chlorine
FRENCH CAMP RV PARK LLC	3919 E FRENCH CAMP RD	PR0506211	7/8/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Major violations corrected, chlorine levels have risen to 2.0 PPM.
FRENCH CAMP RV PARK LLC	3919 E FRENCH CAMP RD	PR0506211	8/3/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	POOL RE-OPENED pH has been adjusted to 7.6.
HAMPTON INN & SUITES	103 E LOUISE AVE	PR0526184	7/29/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool is permitted to be reopened.
HAMPTON INN & SUITES LODI	1337 S BECKMAN RD	PR0528205	6/4/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool is closed due to major violations detected and to be corrected.
HAMPTON INN & SUITES LODI	1337 S BECKMAN RD	PR0528205	6/5/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	All major and minor violations had been corrected. Pool is re opened.
HARBOR ISLE APARTMENTS	8429 MARINERS DR	PR0360367	7/22/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed.
HARBOR ISLE APARTMENTS	8429 MARINERS DR	PR0360367	7/22/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened.
HARVEST GOLD LP - VILLA DE ORO	39 GATEWAY CT	PR0360502	6/14/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3612 - PUBLIC POOL/SPA - ADDITIONAL	pool closed
HARVEST GOLD LP - VILLA DE ORO	39 GATEWAY CT	PR0360301	6/14/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed

HARVEST GOLD LP - VILLA DE ORO	39 GATEWAY CT	PR0360301	6/22/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	pool reopens
HOLIDAY INN EXPRESS	5045 S HWY 99	PR0518087	6/25/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closure for the pool due to the pH being higher than 8.0.
HOLIDAY INN EXPRESS	5045 S HWY 99	PR0518087	6/26/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Facility was re-opened after violations have been corrected and pH had been stabilized to 7.6.
HOLIDAY INN EXPRESS HOTEL & SUITES	179 COMMERCE AVE	PR0522085	6/25/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to high chlorine and high pH.
HOLIDAY INN EXPRESS HOTEL & SUITES	179 COMMERCE AVE	PR0522085	6/26/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened (major violations corrected)
IN SHAPE CITY - STOCKTON	7920 KELLEY DR	PR0508070	7/23/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Reopened Pool
IN SHAPE HEALTH CLUB - WEST LANE	1074 E BIANCHI RD	PR0360182	6/17/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool is closed due to major violation detected.
IN SHAPE HEALTH CLUB - WEST LANE	1074 E BIANCHI RD	PR0360182	6/18/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Main pool is re opened after major violations corrected.
IRON HORSE APARTMENTS	2506 COUNTRY CLUB BLVD	PR0360339	6/2/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to high chlorine and high pH
IRON HORSE APARTMENTS	2506 COUNTRY CLUB BLVD	PR0360339	6/5/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	pool re-opened
JUNIPER APARTMENTS	1201 E ATHERTON DR	PR0537295	6/22/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED - free chlorine is 0.2 ppm
JUNIPER APARTMENTS	1201 E ATHERTON DR	PR0537295	6/23/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-opened pool this date.
LA QUINTA MOTOR INN #625	2710 W MARCH LN	PR0360065	6/17/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to high chlorine
LA QUINTA MOTOR INN #625	2710 W MARCH LN	PR0360065	6/14/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to low pH
LA QUINTA MOTOR INN #625	2710 W MARCH LN	PR0360065	6/19/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to zero chlorine, low pH, and water cloudy
LA QUINTA MOTOR INN #625	2710 W MARCH LN	PR0360065	6/21/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	ok to reopen pool
LA QUINTA MOTOR INN #625	2710 W MARCH LN	PR0360065	6/16/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened
LAKESHORE MEADOWS APTS SOUTH	2080 SYLVAN WAY	PR0360560	6/8/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed pH 8.0.

LAKESHORE MEADOWS APTS SOUTH	2080 SYLVAN WAY	PR0360560	6/16/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-opened pool.
LAMPLITER	1426 TELEGRAPH AVE APT 1	PR0360383	6/6/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to low chlorine level.
LAMPLITER	1426 TELEGRAPH AVE APT 1	PR0360383	6/9/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened
LAUREL GLEN APARTMENTS	574 BUTTON AVE	PR0360066	6/10/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Major violation corrected
LINCOLN COURTYARD	443 GLENDORA AVE	PR0360419	6/14/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to low pH
LINCOLN COURTYARD	443 GLENDORA AVE	PR0360419	6/15/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	ok to re-open pool
LINCOLN COURTYARD	531 GLENDORA AVE	PR0360384	6/14/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to gate not latching, hook not attached to a pole ,and low chlorine.
LINCOLN COURTYARD	531 GLENDORA AVE	PR0360384	6/13/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	pool re-opened
MARINERS COVE APARTMENTS	8531 MARINERS DR	PR0360083	7/1/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-opened pool.
MEADOWGREEN APARTMENTS	211 W SAN CARLOS WAY	PR0360084	6/20/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to low pH and zero free chlorine
MEADOWGREEN APARTMENTS	211 W SAN CARLOS WAY	PR0360084	7/11/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to low pH
MEADOWGREEN APARTMENTS	211 W SAN CARLOS WAY	PR0360084	7/10/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed due to low ph and one drain cover semi out of place
MEADOWGREEN APARTMENTS	211 W SAN CARLOS WAY	PR0360084	6/26/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	OK to reopen pool. Chlorine and pH levels are now acceptable.
MEADOWGREEN APARTMENTS	211 W SAN CARLOS WAY	PR0360084	7/13/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened
MICROTEL INN & SUITES	861 W CLOVER RD	PR0527869	6/21/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool Closed
MICROTEL INN & SUITES	861 W CLOVER RD	PR0527869	8/1/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened at 1:45pm
MICROTEL INN & SUITES	861 W CLOVER RD	PR0527869	6/22/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-open pool.
MOTEL 6	2654 W MARCH LN	PR0360565	6/20/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to gate not closing and no life ring.

MOTEL 6	2654 W MARCH LN	PR0360565	6/26/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed-gate not self latching, zero chlorine, low pH, and cloudy water
MOTEL 6	2654 W MARCH LN	PR0360565	7/15/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened. Chlorine and pH level now acceptable.
MOTEL 6 #1323	6717 PLYMOUTH RD	PR0360001	6/28/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed due to high ph and free chlorine.
MUSD-EAST UNION HIGH SCHOOL	1700 N UNION ST	PR0360572	8/4/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3616 - PUBLIC POOL/SPA - EXEMPT	Pool closed due to high chlorine and high pH.
NORTHGATE COMMONS APARTMENTS	510 NORTHGATE DR	PR0360095	8/3/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED
NORTHGATE COMMONS APARTMENTS	510 NORTHGATE DR	PR0360095	8/3/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	POOL RE-OPENED
NORTHGATE MANOR APARTMENTS	360 NORTHGATE DR	PR0360096	6/19/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to low chlorine.
NORTHGATE MANOR APARTMENTS	360 NORTHGATE DR	PR0360096	6/19/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened. Chlorine at 4.4 ppm.
NORTHGATE TOWERS APARTMENTS	470 NORTHGATE DR	PR0360094	6/19/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to low chlorine.
NORTHGATE TOWERS APARTMENTS	470 NORTHGATE DR	PR0360094	6/19/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened. Chlorine at 6.0 ppm.
OAKWOOD SHORES OWNERS ASSOCIATION	1699 BELLA LAGO WAY	PR0535460	6/21/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed (pH too high, chlorine too low)
OAKWOOD SHORES OWNERS ASSOCIATION	1699 BELLA LAGO WAY	PR0535460	6/26/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened (major violations corrected)
ORCHARD RV PARK	2701 E HWY 132	PR0360010	8/15/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened at 10:25am
ORCHARD RV PARK	2701 E HWY 132	PR0360010	7/26/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-opened pool
ORCHARD RV PARK	2701 E HWY 132	PR0360010	9/9/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Ok to re-open.
PACIFIC HEIGHTS VILLAS	126 E JAMESTOWN ST	PR0360493	8/15/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	pool reopened.
PACIFIC PALMS APARTMENTS	4415 N PERSHING AVE	PR0360417	6/10/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to high free chlorine
PACIFIC PALMS APARTMENTS	4415 N PERSHING AVE	PR0360417	6/11/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Ok to reopen pool

PACIFIC VILLAS LP	4550 SHELLEY CT	PR0360408	9/28/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	pool reopens
PACIFIC VILLAS LP	4550 SHELLEY CT	PR0360408	7/22/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	pool (remains) closed.
PARADISE APARTMENTS	1441 PARKER AVE	PR0360424	8/19/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened. Major violations corrected.
PARK PLACE APARTMENTS	1257 CROM ST	PR0360563	6/27/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to faulty light fixture
PARK PLACE APARTMENTS	1257 CROM ST	PR0360563	6/28/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Major violation corrected.
PASEO VILLAS APTS	801 E ATHERTON DR	PR0524195	6/7/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Major violations (pH and chlorine)
PASEO VILLAS APTS	801 E ATHERTON DR	PR0524195	6/7/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Major violations corrected
PINEWOOD COVE COA	3219 DE OVAN AVE	PR0360433	6/22/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed due to high chlorine
PINEWOOD COVE COA	3219 DE OVAN AVE	PR0360433	6/27/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	ok to re-open pool
PLYMOUTH BAY APARTMENTS	6723 PLYMOUTH RD	PR0360108	7/11/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Free chlorine and pH were verified. Ok to reopen the pool.
POINT QUEST EDUCATION	12755 N HWY 88	PR0360311	6/6/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed. See OIR
POINT QUEST EDUCATION	12755 N HWY 88	PR0360311	6/20/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopens
POLO RUN APARTMENTS	8162 PALISADES DR	PR0360184	8/31/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-opened pool.
POOL HOA, THE	131 S ALLEN DR	PR0360435	8/24/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed
POOL HOA, THE	131 S ALLEN DR	PR0360435	8/24/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	pool opens
QUALITY INN & SUITES	16855 S HARLAN RD	PR0506103	8/2/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool has pH balance to 7.2 and free chlorine to 7.0 ppm. Pool is permitted to be reopened.
QUINCY GARDENS APARTMENTS	221 QUINCY ST	PR0360125	6/29/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed
QUINCY GARDENS APARTMENTS	221 QUINCY ST	PR0360125	7/1/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool was reopened
RED ROOF INN	1707 W FREMONT ST	PR0360046	6/21/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed

RED ROOF INN	1707 W FREMONT ST	PR0360046	6/23/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool was re-opened
REGENCY CONDOMINIUM ASSN	2421 COUNTRY CLUB BLVD	PR0360524	6/8/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3612 - PUBLIC POOL/SPA - ADDITIONAL	Pool closed. Water was green and pH was low
RESIDENCE INN BY MARRIOT	3240 W MARCH LN	PR0507211	6/17/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to low chlorine
RESIDENCES AT BROOKSIDE	3939 N PERSHING AVE	PR0360313	6/17/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due low chlorine
RESIDENCES AT BROOKSIDE	3939 N PERSHING AVE	PR0360313	6/28/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened
RESIDENCES AT BROOKSIDE	3939 N PERSHING AVE	PR0360313	6/15/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	ok to re-open pool
RIPON GARDEN APTS	1663 N RIPON RD	PR0544736	8/15/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Major violations corrected. reopen pool
RIVERBANK APARTMENTS POOL	4433 CONTINENTAL WAY	PR0360119	7/26/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool is re opened as major violation is corrected. Free chlorine is 7ppm.
RIVERBANK APARTMENTS POOL	4433 CONTINENTAL WAY	PR0360119	6/24/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopens
RIVERS EDGE	505 PIONEER DR	PR0360107	6/9/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool is reopened
ROSELAWN APARTMENTS	1835 ROSELAWN AVE	PR0360441	6/26/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	ok to re-open pool
SAHARA MOBILE COURT	2340 SANGUINETTI LN	PR0360123	6/15/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened.
SCHOONER LANDING APARTMENTS	7100 SHORELINE DR	PR0360552	7/29/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	pool reopen
SIENNA PLACE APARTMENTS	794 BUTTON AVE	PR0360405	6/21/2019	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to high chlorine and lack of life ring.
SIENNA PLACE APARTMENTS	794 BUTTON AVE	PR0360405	6/24/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED. Free chlorine level is above limit.
SIENNA PLACE APARTMENTS	794 BUTTON AVE	PR0360405	6/25/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened. Major violations corrected.
SIENNA PLACE APARTMENTS	794 BUTTON AVE	PR0360405	6/24/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	POOL RE-OPENED. Free chlorine level is now between 2.0 and 10.0 ppm.
SOUTHLAND MOBILE HOME PARK	1624 N HWY 99	PR0360132	8/28/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened. Major violation corrected.
SPRING CREEK COUNTRY CLUB	1580 E SPRING CREEK DR	PR0360451	8/7/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Major violation corrected. Reopened pool.
STOCKTON TOWNHOUSE APARTMENTS	1540 TELEGRAPH AVE	PR0360455	7/15/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened. Free chlorine now acceptable.

STOCKTON VERDE MOBILE HOME PRK	4900 N HWY 99	PR0360139	6/23/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopens
STONETREE CONDOMINIUMS	1819 S CHEROKEE LN	PR0360140	9/19/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool is reopened after fixing the sand filter.
STONEWOOD HOMEOWNERS ASSN	8704 STONEWOOD DR	PR0360529	7/13/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3612 - PUBLIC POOL/SPA - ADDITIONAL	Pool closed.
SUTTER APARTMENTS	430 SUTTER ST	PR0360465	8/17/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to no chlorine, high pH and the pump is not turned on.
SUTTER APARTMENTS	430 SUTTER ST	PR0360465	8/19/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Major violation corrected. pool reopened
TIENDA PLACE HOMEOWNERS ASSOC	1352 LAKESHORE DR	PR0523177	8/25/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed.
TORCELLO APARTMENTS	1633 BIANCHI A3	PR0518496	6/7/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	pool closed see OIR
TRACY PARK APARTMENTS	2800 N TRACY BLVD	PR0360152	8/9/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened
TRACY PARK APARTMENTS	2800 N TRACY BLVD	PR0360152	8/2/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-opened.
UNION COURT APARTMENTS	940 S UNION RD	PR0360326	8/9/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED.
UNION COURT APARTMENTS	940 S UNION RD	PR0360326	8/11/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	RE-OPENED POOL
UOP - TOWNHOUSE APARTMENTS	4030 N PERSHING AVE	PR0360536	7/11/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to non functional pump , low chlorine and low pH.
UOP - TOWNHOUSE APARTMENTS	4030 N PERSHING AVE	PR0360536	6/24/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened
UOP - TOWNHOUSE APARTMENTS	4030 N PERSHING AVE	PR0360536	7/14/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened
VALVERDE APARTMENTS	633 E STEWART ST	PR0360160	8/3/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED
VALVERDE APARTMENTS	633 E STEWART ST	PR0360160	8/9/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed: no chlorine and electrical hazard.
VALVERDE APARTMENTS	633 E STEWART ST	PR0360160	8/11/2017	335 - REINSPECTION (Actual Time)	3611 - PUBLIC POOL/SPA - PRIMARY	Pool Closed no one to open pool for re inspection at 633E Stewart St, Manteca. appointment taken for Monday 08/14/17 at 10.00am
VALVERDE APARTMENTS	633 E STEWART ST	PR0360160	8/14/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	OK to re-open the pool. Major violations corrected.

VALVERDE APARTMENTS	633 E STEWART ST	PR0360160	8/3/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	POOL RE-OPENED
VENETIAN BRIDGES APTS EAST	2101 ROSEMARIE LN	PR0360276	7/8/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed
VENETIAN BRIDGES APTS EAST	2101 ROSEMARIE LN	PR0360162	7/8/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3612 - PUBLIC POOL/SPA - ADDITIONAL	Pool closed
VENETIAN BRIDGES APTS EAST	2101 ROSEMARIE LN	PR0360276	7/14/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened
VENETIAN BRIDGES APTS WEST	2317 ROSEMARIE LN	PR0360278	7/8/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed
VENETIAN BRIDGES APTS WEST	2317 ROSEMARIE LN	PR0360278	7/14/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened
VENETIAN PARK APARTMENTS	1540 MOSAIC WAY	PR0360274	8/16/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3612 - PUBLIC POOL/SPA - ADDITIONAL	POOL CLOSED
VENETIAN PARK APARTMENTS	1540 MOSAIC WAY	PR0360161	6/25/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened
VILLA COURT APARTMENTS	1222 S HUTCHINS ST	PR0360485	8/19/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed.
VILLA COURT APARTMENTS	1222 S HUTCHINS ST	PR0360485	8/22/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened.
VILLAGIO APARTMENTS	550 SANDY LN	PR0528055	8/4/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED
VILLAGIO APARTMENTS	550 SANDY LN	PR0528055	7/31/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Major violation corrected. Reopen pool
VILLAGIO APARTMENTS	550 SANDY LN	PR0528055	8/5/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	RE-OPENED POOL
VINTAGE MANOR APARTMENTS	164 FRONTAGE RD	PR0360490	8/6/2015	002 - ROUTINE SUPPLEMENTAL ACTIVITY - Operating Permit	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed on 8-5-15. Called facility to see if they were ready to re-open. Per Mark Keson, Manager, the pool is still closed and he will call me tomorrow.
VINTAGE MANOR APARTMENTS	164 FRONTAGE RD	PR0360490	8/1/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED
VINTAGE MANOR APARTMENTS	164 FRONTAGE RD	PR0360490	7/19/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened. Major violations corrected (pH lowered and light put back into place).
VINTAGE MANOR APARTMENTS	164 FRONTAGE RD	PR0360490	8/4/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	POOL RE-OPENED
VINTAGE SQUARE APTS	1176 ROSEMARIE LN	PR0360100	6/22/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to damaged fence

VINTAGE SQUARE APTS	1176 ROSEMARIE LN	PR0360100	6/22/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened
WESTPOINTE APARTMENTS NE SPA	6465 N WEST LN	PR0360595	7/8/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re opened.
WESTPOINTE APARTMENTS NE SPA	6465 N WEST LN	PR0360595	9/23/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopens
WESTPOINTE APARTMENTS SE POOL	6465 N WEST LN	PR0360578	7/8/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool reopened.
WESTWOOD VILLAGE APARTMENTS	1212 W CENTER ST	PR0360185	6/30/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed due to an potential safety hazard (grounding wire sparked thus causing the pool pump and filter to shut off). OK to re-open pool when service person visits facility and gets the pump up and running again.
WESTWOOD VILLAGE APARTMENTS	1212 W CENTER ST	PR0360185	6/30/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	OK to re-open pool. Received call from Danielle Dewing (Community Director) at 4:15pm. The pool pump and filter are up and running.
WINTERS GLEN APTS / ROBERT AVE APTS	145 ROBERT AVE	PR0360612	7/25/2017	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed at 1:15pm. High chlorine and low pH.
WINTERS GLEN APTS / ROBERT AVE APTS	145 ROBERT AVE	PR0360612	7/28/2017	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Re-opened pool at 10:50 am.
WOODBIDGE GOLF & COUNTRY CLUB	800 E WOODBRIDGE RD	PR0360498	8/2/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed.
WOODBIDGE GOLF & COUNTRY CLUB	800 E WOODBRIDGE RD	PR0360498	8/2/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Pool re-opened.
WOODBIDGE VILLAGE CONDOMINIUM	18644 LILAC ST	PR0360188	8/2/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	Pool closed.
WOODBIDGE VILLAGE CONDOMINIUM	18644 LILAC ST	PR0360188	7/18/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Reopened Pool
YOSEMITE APARTMENTS	141 S EL PORTAL AVE	PR0360501	7/11/2019	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	Major violation corrected. Ok to reopen pool.
YOSEMITE ARMS APARTMENTS	1161 E YOSEMITE AVE	PR0360500	6/24/2016	064 - FACILITY CLOSURE NOTICE ISSUED - HEALTH HAZARD	3611 - PUBLIC POOL/SPA - PRIMARY	POOL CLOSED. Free chlorine level is above limit.
YOSEMITE ARMS APARTMENTS	1161 E YOSEMITE AVE	PR0360500	6/24/2016	063 - FACILITY REOPENED	3611 - PUBLIC POOL/SPA - PRIMARY	POOL RE-OPENED. Free chlorine level is now between 2.0 to 10.0 ppm.